

---

# Skylight and conservatory roller shutters — Resistance to snow load — Test method

The European Standard EN 12833:2001 has the status of a  
British Standard

ICS 91.060.50

## National foreword

This British Standard is the official English language version of EN 12833:2001.

The UK participation in its preparation was entrusted by Technical Committee B/538, Doors, windows, shutters, hardware and curtain walling, to Subcommittee B/538/3, Domestic shutters and blinds, which has the responsibility to:

- aid enquirers to understand the text;
- present to the responsible European committee any enquiries on the interpretation, or proposals for change, and keep the UK interests informed;
- monitor related international and European developments and promulgate them in the UK.

A list of organizations represented on this subcommittee can be obtained on request to its secretary.

### Cross-references

The British Standards which implement international or European publications referred to in this document may be found in the BSI Standards Catalogue under the section entitled "International Standards Correspondence Index", or by using the "Find" facility of the BSI Standards Electronic Catalogue.

A British Standard does not purport to include all the necessary provisions of a contract. Users of British Standards are responsible for their correct application.

Compliance with a British Standard does not of itself confer immunity from legal obligations.

This British Standard, having been prepared under the direction of the Sector Committee for Building and Civil Engineering, was published under the authority of the Standards Committee and comes into effect on 15 June 2001

### Summary of pages

This document comprises a front cover, an inside front cover, the EN title page, pages 2 to 8, an inside back cover and a back cover.

The BSI copyright date displayed in this document indicates when the document was last issued.

### Amendments issued since publication

Amd. No.	Date	Comments

ICS 91.010.30; 91.060.50

English version

## Skylight and conservatory roller shutters - Resistance to snow load - Test method

Volets roulants pour fenêtres de toit et véranda -  
Résistance à la charge de neige - Méthode d'essai

Rolläden für Dachflächenfenster und Wintergärten -  
Widerstand gegen Schneelast - Prüfverfahren

This European Standard was approved by CEN on 7 March 2001.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Czech Republic, Denmark, Finland, France, Germany, Greece, Iceland, Ireland, Italy, Luxembourg, Netherlands, Norway, Portugal, Spain, Sweden, Switzerland and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION  
COMITÉ EUROPÉEN DE NORMALISATION  
EUROPÄISCHES KOMITEE FÜR NORMUNG

---

Management Centre: rue de Stassart, 36 B-1050 Brussels

## CONTENTS

Page

Foreword.....	3
1 Scope.....	3
2 Normative references .....	3
3 Terms and definitions.....	4
4 Test conditions .....	4
4.1 Test principle.....	4
4.2 Sample dimensions.....	5
4.3 Preparation of the test.....	6
5 Test methods .....	7
6 Expression of results .....	7
7 Test report.....	8

## Foreword

This European Standard has been prepared by Technical Committee CEN/TC 33 "Doors, windows, shutters, building hardware and curtain walling", the secretariat of which is held by AFNOR.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by October 2001, and conflicting national standards shall be withdrawn at the latest by October 2001.

It is part of a series of standards dealing with blinds and shutters for buildings as defined in prEN 12216:1995.

Snow effects on sloping shutters result in pressures which are reproduced by the following tests.

The test method is linked to performance requirements for shutters specified in prEN 13659:1999.

According to the CEN/CENELEC Internal Regulations, the national standards organizations of the following countries are bound to implement this European Standard: Austria, Belgium, Czech Republic, Denmark, Finland, France, Germany, Greece, Iceland, Ireland, Italy, Luxembourg, Netherlands, Norway, Portugal, Spain, Sweden, Switzerland and the United Kingdom.

## 1 Scope

This European Standard specifies the methods of test to be applied to evaluate the snow load resistance performances of shutters inclined less than 60° from the horizontal, those resistant either alone or in mechanical association with the glazing.

It applies to

- skylight roller shutters ;
- conservatory roller shutters.

## 2 Normative references

This European Standard incorporates by dated or undated reference, provisions from other publications. These normative references are cited at the appropriate places in the text and the publications are listed hereafter. For dated references, subsequent amendments to or revisions of any of these publications apply to this European Standard only when incorporated in it by amendment or revision. For undated references, the latest edition of the publication referred to applies (including amendments).

EN 1932	"External blinds and shutters - Resistance to wind loads - Method of testing"
prEN 12216:1995	"Shutters, external blinds, internal blinds – Terminology, glossary and definitions"
EN 13527	"Shutters and blinds - Measurement of operating force - Test methods"
prEN 13659:1999	"Shutters – Performance requirements including safety"

### 3 Terms and definitions

For the purposes of this European Standard, the terms and definitions given in prEN 12216:1995 and the following apply.

#### 3.1

##### **direct nominal test pressure $p_N$**

uniform pressure or loads reproducing a uniform pressure, exerted on the external face of the test sample

#### 3.2

##### **safety pressure $p_s$**

uniform pressure or loads set out reproducing a uniform pressure under which there shall be no rupture of the product. The safety pressure  $p_s$  is linked to the nominal pressure  $p_N$  by the coefficient  $f_s$

#### 3.3

##### **dimensions**

##### 3.3.1

##### **height H**

visible height of the curtain including the bottom lath

##### 3.3.2

##### **width L**

visible width of the curtain

##### 3.3.3

##### **surface of loading**

given by  $L \times H$

#### 3.4

##### **distance d**

distance between the internal face of the curtain and the glazing, measured with the curtain in the fully extended position

### 4 Test conditions

#### 4.1 Test principle

To verify the holding of shutters under nominal pressure  $p_N$  and safety pressure  $p_s$  representing the particular applicable snow pressure.

Two forms of resistance to snow load are envisaged.

- a) The shutter resists alone the snow pressure without contact with the glazing,

The pressure is applied gradually to  $p_N$  and the corresponding displacement in the center of the curtain measured.

- b) The shutter resists the snow pressure together with the mechanical association with the glazing.

The shutter is tested in association with a rigid panel, parallel to the curtain, representing the glazing, sufficiently rigid to withstand the test pressures without sustaining damage that could interfere with the results.

Under  $p_N$ , the curtain shall be in contact with this panel.

#### 4.2 Sample dimensions

The chosen dimensions are linked to the type of resistance envisaged :

a) The shutter alone resists the snow load without contact with the glazing

To be representative of a range of sizes, the sample submitted shall be the maximum width  $L_1$  relative to the maximum height  $H_1$  possible for this width.

Products less wide and no greater in surface area than the surface area of the sample tested  $S_1 = L_1 \times H_1$  will be assumed to resist the same snow load,  $p$  (See Figure 1)

b) The shutter resists the snow load together with the mechanical association of the glazing.

To be representative of a range of sizes, the sample submitted shall be the minimum width  $L_2$ ,

- relative to a height  $H_2$  possible for this width,

- ensuring the contact between the curtain and the glazing for the maximum distance  $d$  proposed.

Wider products and with a surface area equal to  $S_{max} = L_2 \times H_0$ , will be assumed to resist the same snow pressure  $p$ , with the maximum distance  $d$ , between the curtain and the glazing (See Figure 2)




Figure 1 The shutter resists alone the snow load -  
Area of allowable dimensions




Figure 2 The shutter resists together with the mechanical association of the glazing - Area of allowable dimensions

### 4.3 Preparation of the test

#### 4.3.1 Positioning of the shutter

a) the shutter alone resists the snow load without contact with the glazing

The shutter is mounted on a rigid frame and equipped with the operating mechanism and is installed using the fixings according to manufacturer instruction.

b) the shutter resists the snow load together with mechanical association of the glazing

Same mounting as a), the frame being equipped with the rigid panel representing the glazing.

This panel is placed at a distance  $1,2 d$  from the curtain,  $d$  being the maximum distance between the shutter and glazing stated by the manufacturer.

#### 4.3.2 Carrying out of the loading

The curtain is loaded uniformly :

- either in a horizontal positioning so that the effect of the loading produces a uniform pressure. In the case of use of individual loads, nine loads per  $m^2$  minimum shall be distributed evenly over the curtain ;
- or in a vertical positioning for the test using air pressure of a pneumatic type. If necessary, the loading is achieved with the help of a thin polyester film or similar material which will not add to the resistance of the shutter. The test apparatus is that described in EN 1932 for wind test for shutters (accuracy 5% of  $p_N$ ).

If the shutter resists together with the glazing, the rigid panel representing the glazing shall be perforated ( $5 \text{ cm}^2$  in holes per  $m^2$ ) not to put under pressure the space between the shutter and the glazing.

#### 4.3.3 Test loads

For the particular applicable snow pressure  $p$ , the nominal pressure  $p_N$  and the safety pressure  $p_S$  are as follows :

**Curtain in the horizontal positioning :**

Direct nominal pressure	$p_N = p$
Safety pressure	$p_S = f_S \times p$

**Curtain in a vertical positioning :** It is necessary to realize a uniform pre-loading, equal to the weight of the curtain by application of a pressure  $p_0$  so that :

Direct nominal pressure	$p_N = p + p_0$
Safety pressure	$p_S = f_S \times p + p_0$



- After applying the safety pressure  $p_s$  :
  - Exit from the guide rails - yes/no
  - Fracture of the laths or guide rails - yes/no

Are also given

- The snow pressure  $p$  corresponding to the test, expressed in  $N/m^2$ ,
- The type of resistance of the shutter to the snow loads
  - shutter alone, or
  - shutter in association together with a glazing located at the maximum distance  $d$  from the shutter, expressed in mm.
- The associated dimensional limits
  - shutter alone : maximum width  $L_1$  and maximum surface area  $S_1$  allowable, or
  - shutter in association together with a glazing at the distance  $d$  : minimum width  $L_2$  and maximum surface area  $S_{max}$  allowable.
- For shutter resisting alone, the value of the deflection at the centre of the curtain for the snow test pressure.

## 7 Test report

The test report contains the following informations :

- a) The necessary descriptions to allow identification of the product (list of components of the product, type of laths, etc.) ;
- b) The details relative to the type, dimensions, constituent materials, form and make up of the product and its conformity with drawings supplied by the manufacturer ;
- c) Complete details of accessories, bracketry and operating mechanism ;
- d) Dimensional limits of the product - width, height, surface area, slopes, etc.) ;
- e) Dimensions of the product tested ;
- f) The results obtained expressed according to clause 6 ;
- g) The name of the test laboratory (laboratory or firm), name of the responsible person ;
- h) The date of the test ;
- i) Reference to this standard.



---

## BSI — British Standards Institution

BSI is the independent national body responsible for preparing British Standards. It presents the UK view on standards in Europe and at the international level. It is incorporated by Royal Charter.

### Revisions

British Standards are updated by amendment or revision. Users of British Standards should make sure that they possess the latest amendments or editions.

It is the constant aim of BSI to improve the quality of our products and services. We would be grateful if anyone finding an inaccuracy or ambiguity while using this British Standard would inform the Secretary of the technical committee responsible, the identity of which can be found on the inside front cover. Tel: 020 8996 9000. Fax: 020 8996 7400.

BSI offers members an individual updating service called PLUS which ensures that subscribers automatically receive the latest editions of standards.

### Buying standards

Orders for all BSI, international and foreign standards publications should be addressed to Customer Services. Tel: 020 8996 9001. Fax: 020 8996 7001. Standards are also available from the BSI website at <http://www.bsi-global.com>.

In response to orders for international standards, it is BSI policy to supply the BSI implementation of those that have been published as British Standards, unless otherwise requested.

### Information on standards

BSI provides a wide range of information on national, European and international standards through its Library and its Technical Help to Exporters Service. Various BSI electronic information services are also available which give details on all its products and services. Contact the Information Centre. Tel: 020 8996 7111. Fax: 020 8996 7048.

Subscribing members of BSI are kept up to date with standards developments and receive substantial discounts on the purchase price of standards. For details of these and other benefits contact Membership Administration.

Tel: 020 8996 7002. Fax: 020 8996 7001. Further information about BSI is available on the BSI website at <http://www.bsi-global.com>.

### Copyright

Copyright subsists in all BSI publications. BSI also holds the copyright, in the UK, of the publications of the international standardization bodies. Except as permitted under the Copyright, Designs and Patents Act 1988 no extract may be reproduced, stored in a retrieval system or transmitted in any form or by any means – electronic, photocopying, recording or otherwise – without prior written permission from BSI.

This does not preclude the free use, in the course of implementing the standard, of necessary details such as symbols, and size, type or grade designations. If these details are to be used for any other purpose than implementation then the prior written permission of BSI must be obtained.

If permission is granted, the terms may include royalty payments or a licensing agreement. Details and advice can be obtained from the Copyright Manager. Tel: 020 8996 7070.