
Glass in building — Determination of energy balance value — Calculation method

The European Standard EN 14438:2002 has the status of a
British Standard

ICS 81.040.20

National foreword

This British Standard is the official English language version of EN ISO 14438:2002. It is identical with ISO 14438:2002.

The UK participation in its preparation was entrusted by Technical Committee B/520, Glass and glazing in building, to Subcommittee B/520/4, Properties and glazing methods, which has the responsibility to:

- aid enquirers to understand the text;
- present to the responsible international/European committee any enquiries on the interpretation, or proposals for change, and keep the UK interests informed;
- monitor related international and European developments and promulgate them in the UK.

A list of organizations represented on this subcommittee can be obtained on request to its secretary.

Cross-references

The British Standards which implement international or European publications referred to in this document may be found in the BSI Standards Catalogue under the section entitled "International Standards Correspondence Index", or by using the "Find" facility of the BSI Standards Electronic Catalogue.

A British Standard does not purport to include all the necessary provisions of a contract. Users of British Standards are responsible for their correct application.

Compliance with a British Standard does not of itself confer immunity from legal obligations.

This British Standard, having been prepared under the direction of the Building and Civil Engineering Sector Policy and Strategy Committee, was published under the authority of the Standards Policy and Strategy Committee on 24 June 2002

Summary of pages

This document comprises a front cover, an inside front cover, the EN ISO title page, pages 2 to 11 and a back cover.

The BSI copyright date displayed in this document indicates when the document was last issued.

Amendments issued since publication

Amd. No.	Date	Comments

© BSI 24 June 2002

ISBN 0 580 38794 1

ICS 81.040.20

English version

Glass in building - Determination of energy balance value -
Calculation method (ISO 14438:2002)

Verre dans la construction - Détermination de la valeur du
bilan énergétique - Méthode de calcul (ISO 14438:2002)

Glas im Bauwesen - Bestimmung des Energiebilanz-
Wertes - Berechnungsverfahren (ISO 14438:2002)

This European Standard was approved by CEN on 5 March 2002.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Czech Republic, Denmark, Finland, France, Germany, Greece, Iceland, Ireland, Italy, Luxembourg, Malta, Netherlands, Norway, Portugal, Spain, Sweden, Switzerland and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

Management Centre: rue de Stassart, 36 B-1050 Brussels

Contents

	page
Foreword.....	3
1	
Scope.....	4
2 Normative	
references	4
3	
Symbols	4
4 Basic	
formula.....	5
5 Basic material	
properties.....	5 6 Solar
radiation incident, Hp	6
7 Degree day data, Dp.....	6
8 Period of application, p	6
9 Principal values and presentation.....	6
10 Alternative simplification of principal values and presentation.....	7
Annex A (informative) Examples of climatic data p, Dp and Hp.....	8
Annex B (informative) Examples of calculation of the energy balance value	9
Bibliography	1
1	

Foreword

This document (EN ISO 14438:2002) has been prepared by Technical Committee CEN/TC 129 "Glass in building", the secretariat of which is held by IBN, in collaboration with Technical Committee ISO/TC 160 "Glass in building".

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by December 2002, and conflicting national standards shall be withdrawn at the latest by December 2002.

According to the CEN/CENELEC Internal Regulations, the national standards organizations of the following countries are bound to implement this European Standard : Austria, Belgium, Czech Republic, Denmark, Finland, France, Germany, Greece, Iceland, Ireland, Italy, Luxembourg, Malta, Netherlands, Norway, Portugal, Spain, Sweden, Switzerland and the United Kingdom.

A first Formal Vote took place within CEN as prEN 14026 between 2000-10-19 and 2000-12-19.

Annexes A and B are informative.

This standard includes a Bibliography.

1 Scope

This European Standard specifies a calculation method to determine the energy balance value of glazing. This European Standard applies to transparent materials such as glass and combinations of glass used to glaze windows in buildings.

This method is intended to evaluate the balance of heat loss and useful heat gain by solar radiation entering the building through the glazing for a given period by means of an average rate of loss (or gain) of heat called the energy balance value.

The method enables producers to compare the performance of their glazing products. The energy balance value should not be used for energy use or heating capacity calculations in buildings.

2 Normative references

This European Standard incorporates by dated or undated references, provisions from other publications. These normative references are cited at the appropriate places in the text and the publications are listed hereafter. For dated references, subsequent amendments to or revisions of any of these publications apply to this European Standard only when incorporated in it by amendment or revision. For undated references the latest edition of the publication referred to applies (including amendments).

EN 410	Glass in building - Determination of luminous and solar characteristics of glazing
EN 673	Glass in building - Determination of thermal transmittance (U value) - Calculation method
EN 674	Glass in building - Determination of thermal transmittance (U value) - Guarded hot plate method
EN 675	Glass in building - Determination of thermal transmittance (U value) - Heat flow meter method
EN 832	Thermal performance of buildings - Calculation of energy use for heating - Residential buildings

3 Symbols

D	degree days	K·24 h
	utility factor	
H	unobstructed incident solar radiation	kWh/m ²
g	total solar energy transmittance (solar factor)	
U	thermal transmittance (U value)	W/(m ² ·K)
f	factor due to glazing maintenance and shadow effects	
S	function of H and D characterising a given region	W/(m ² ·K)
E	energy balance value	W/(m ² ·K)
Subscripts		
p	period of application	

4 Basic formula

The energy balance value, E , for a given period is calculated according to the following equation: (1)

$$E = U \left(\frac{g f H_p}{D_p} \right)$$

where:

U is the U value of the glazing;

f is the utility factor;

f is the factor due to glazing maintenance and shadow effects;

g is the glazing total solar energy transmittance (solar factor);

H_p is the unobstructed incident solar radiation during the given period;

D_p is the degree day total for the given period.

NOTE An example of calculation is given in annex B.

5 Basic material properties

5.1 U Value (thermal transmittance)

The U value of the glazing is determined by calculation, in accordance with EN 673 or measurement in accordance with EN 674 or EN 675.

5.2 Utility factor,

The utility factor for a building or space in a building is the ratio of the useful heat gains, which displace the functional heating over a defined period, to the total heat gains during the period.

The utility factor is essentially a property of the building design.

The utility factor cannot exceed unity. Its precise value depends on the ability of the building and the control of its heating systems to displace its functional heating load while maintaining desirable temperatures inside.

The utility factor is dependent on the period chosen and the length of the period.

Its value for typical constructions such as windows in buildings lies between 0,4 and 0,8 for the winter heating period and it can be determined experimentally or by calculation in accordance with EN 832. For purposes of comparison of glazing products a utility factor of 0,6 shall be used.

5.3 Glazing total solar energy transmittance (solar factor), g

This is the total transmission of solar heat through the glazing, and is the sum of the direct transmittance of solar radiation and the amount of absorbed radiation which is convected and re-radiated to the interior.

The total solar energy transmittance shall be determined in accordance with EN 410.

5.4 Factor due to glazing maintenance and shadow effects, f

This factor is an allowance for accumulated dirt on the glazing surface and shading effects. For vertical or near vertical ($\pm 15^\circ$) surfaces the value 0,8 shall be used for comparison of glazing products.

6 Solar radiation incident, H_p

The amount of unobstructed solar radiation is described by the factor H_p which is the amount of solar radiation in kWh/m² incident upon the vertical glazing surface during the whole period under consideration.

Data for selected sites are exemplified in annex A.

NOTE Data for sites in Europe are found in [1] of Bibliography.

7 Degree day data, D_p

Degree day units are computed as the difference between the base temperature and the daily average outside temperature. One unit is accumulated for each degree kelvin the average temperature is below the base temperature. Negative values are discarded. This is done for each day of the heating period and summed.

Degree day data are calculated for the local national conditions. Official statistics are published in most countries. The base temperature is the internal design control temperature and shall be defined for the period under consideration. For purposes of comparison a base temperature of 18° C shall be used.

The value used in the equation shall be the total number of degree days (in kelvins · 24 h) for the period under consideration. Examples are given in annex A.

8 Period of application, p

The method of this standard may be used for evaluating the energy balance value of glazing for any chosen period.

For purposes of comparison the period is the "heating season", i.e. the whole period in the months during which functional heating is used in the building. Examples are given in annex A.

9 Principal values and presentation

For the evaluation of the energy balance value (E) of glazing which is used for comparative purposes identical underlying assumptions shall be made.

All the underlying assumptions shall be stated and data prescribed in this standard shall be used.

Statement of underlying assumptions:

- location of use;
- orientation of glazing;
- source of degree day data.

If values of the utility factor and glazing maintenance factor different from 0,6 and 0,8 respectively are used for purposes other than for comparison of products, this shall be stated.

Any publication of energy balance value shall be accompanied by a statement, that the evaluation is based on the full potential incident solar radiation. Any external obstruction which overshadows the window tends to increase the energy balance value. Therefore, in addition to a statement of the underlying assumptions the following complementary statement shall be made:

"This evaluation is applicable only for unobstructed glazing".

The energy balance value shall be expressed in W/(m²·K) rounded to one decimal figure. If the second decimal is five, it shall be rounded to the higher values.

- EXAMPLE 1 1,53 becomes 1,5
 EXAMPLE 2 1,55 becomes 1,6
 EXAMPLE 3 1,549 becomes 1,5

10 Alternative simplification of principal values and presentation

The basic formula can be simplified as follows:

$$E = U_g S \quad (2)$$

where:

$$S = \frac{H_p}{D_p} \quad (3)$$

"S" may be ascribed values corresponding to a region or a country, where the region or country does not extend over a widely diverse climatic range. For each region or country "deemed to satisfy" values of S for the principal orientations are used to characterise the climate, period of application and utility factor of the incident solar radiation as exemplified in annex B.

Annex A (informative)

Examples of climatic data p, Dp and Hp

Table A.1 - Duration of heating season, degree day totals for base temperatures of 18° C and solar radiation incident on vertical surfaces for selected sites

Location	Heating season (Duration inclusive)	Degree day total, Dp (K·24 h)	Solar radiation, Hp (kWh/m ²)		
			North	East/West	South
Belgium (Uccle)	Sept/May	2900	202	350	505
Denmark (Copenhagen)	Sept/May	2936	100	225	420
France Zone H1 (Trappes)	Sept/May	2625	230	410	590
Zone H2 (Carpentras)	Oct/May	2167	235	520	720
Zone H3 (Nice)	Nov/April	1542	150	360	630
Germany (Hamburg)	Sept/May	3267	195	348	505
(Berlin)	Sept/May	3335	203	358	518
(Munich)	Sept/May	3568	242	446	649
Holland (De Bilt)	Sept/May	2935	205	358	522
Italy (Milan)	Oct/March	2159	107	196	346
(Rome)	Nov/March	1401	110	239	442
(Messina)	Nov/March	844	85	191	373
UK (South) (London) (Thames Valley) (Midlands)	Sept/May	2700	200	347	510
UK (North)	Sept/May	3000	197	354	497
UK (Scotland)	Sept/May	3200	176	303	452
Japan (Sapporo)	Sept/June	3757	175	443	709
(Niigata)	Oct/April	2313	124	223	364
(Tokyo)	Nov/April	1599	102	228	440
(Kagoshima)	Nov/April	1200	93	281	533

B.2 Example of calculation from 'deemed to satisfy' S values for a given region or country

Table B.2 - Examples of deemed to satisfy S values for a given region or country

	"Deemed to satisfy" S values for computing the energy balance value W/(m ² ·K)		
ORIENTATION	North	East or West	South
	1,9	2,5	3,2

NOTE The numerical values ascribed in the table above are intended to illustrate the calculation and application of the principle and are not constructed to be similar or typical of any particular region or country.

EXAMPLE 1

Example of calculation of the energy balance value for a conventional double glazing (air filling, no low-e-coating).

U value is 2,9 W/(m²·K)

g is 0,75

The energy balance value is calculated as follows:

$$E = 2,9 - 0,75 S$$

The following results are obtained for each orientation:

Orientation	North	East or West	South
E	1,5	1,0	0,5

EXAMPLE 2

Example of calculation of the energy balance value for a double glazing with a low-e-coating and argon gas filling on the basis of S values in Table B.2.

U value is 1,4 W/(m²·K)

g is 0,65

The energy balance value is calculated as follows:

$$E = 1,4 - 0,65 S$$

The following results are obtained for each orientation:

Orientation	North	East or West	South
E	0,2	-0,21)	-0,7 ¹⁾

1) As the solar gains are higher than the losses the energy balance value becomes negative.

Licensed copy: Lee Shau Kee Library, HKUST, Version correct as of 03/01/2015, (c) The British Standards Institution 2013

Bibliography

- [1] "European Solar Radiation Atlas Volume II: Global and Diffuse Radiation on Vertical and Inclined Surfaces", Edited by W. Palz, Commission of European Communities (1984), EUR 9345

BSI — British Standards Institution

BSI is the independent national body responsible for preparing British Standards. It presents the UK view on standards in Europe and at the international level. It is incorporated by Royal Charter.

Revisions

British Standards are updated by amendment or revision. Users of British Standards should make sure that they possess the latest amendments or editions.

It is the constant aim of BSI to improve the quality of our products and services. We would be grateful if anyone finding an inaccuracy or ambiguity while using this British Standard would inform the Secretary of the technical committee responsible, the identity of which can be found on the inside front cover. Tel: +44 (0)20 8996 9000. Fax: +44 (0)20 8996 7400.

BSI offers members an individual updating service called PLUS which ensures that subscribers automatically receive the latest editions of standards.

Buying standards

Orders for all BSI, international and foreign standards publications should be addressed to Customer Services. Tel: +44 (0)20 8996 9001.

Fax: +44 (0)20 8996 7001. Email: orders@bsi-global.com. Standards are also available from the BSI website at <http://www.bsi-global.com>.

In response to orders for international standards, it is BSI policy to supply the BSI implementation of those that have been published as British Standards, unless otherwise requested.

Information on standards

BSI provides a wide range of information on national, European and international standards through its Library and its Technical Help to Exporters Service. Various BSI electronic information services are also available which give details on all its products and services. Contact the Information Centre. Tel: +44 (0)20 8996 7111. Fax: +44 (0)20 8996 7048. Email: info@bsi-global.com.

Subscribing members of BSI are kept up to date with standards developments and receive substantial discounts on the purchase price of standards. For details of these and other benefits contact Membership Administration. Tel: +44 (0)20 8996 7002. Fax: +44 (0)20 8996 7001.

Email: membership@bsi-global.com.

Information regarding online access to British Standards via British Standards Online can be found at <http://www.bsi-global.com/bsonline>.

Further information about BSI is available on the BSI website at <http://www.bsi-global.com>.

Copyright

Copyright subsists in all BSI publications. BSI also holds the copyright, in the UK, of the publications of the international standardization bodies. Except as permitted under the Copyright, Designs and Patents Act 1988 no extract may be reproduced, stored in a retrieval system or transmitted in any form or by any means – electronic, photocopying, recording or otherwise – without prior written permission from BSI.

This does not preclude the free use, in the course of implementing the standard, of necessary details such as symbols, and size, type or grade designations. If these details are to be used for any other purpose than implementation then the prior written permission of BSI must be obtained.

Details and advice can be obtained from the Copyright & Licensing Manager. Tel: +44 (0)20 8996 7070. Fax: +44 (0)20 8996 7553. Email: copyright@bsi-global.com.